



City of Sanibel

ADDENDUM NO. 2
April 15, 2026

RE: Sanibel Slough Hydraulic Dredging Project (ITB-NR-1-2026/BS) Proposal due date: May 07, 2026 @ 2:30PM

FROM: City of Sanibel
800 Dunlop Road
Sanibel, FL 33957

TO: Prospective Bidders and Others Concerned

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original document.

A. Questions and Answers

- Question No. 1: Drawing C09, Erosion Control Plan, The Silt fence, soil tracking prevention device, and turbidity barrier call outs are grainy and not legible. Can you get the engineer to send an updated drawing
- Response No. 1: Please see the enclosed Sheet C09.
- Question No. 2: What is the best address to use to locate the staging area?
- Response No. 2: The parcel strap numbers are 30-46-23-T2-U9622.2518 (no address), 30-46-23-T2-00016.0090 (855 Elinor Way), 30-46-23-T2-00016.0410 (845 Elinor Way), and 30-46-23-T2-00016.0080 (1119 Junonia Street).
- Question No. 3: Will we be allowed to use chemical programs that are acceptable by the state?
- Response No. 3: Chemical programs for coagulation–flocculation may be acceptable, subject to City receiving a detailed plan from Contractor and receiving written approval of the plan from the Florida Department of Environmental Protection.
- Question No.4: Are we allowed to clear trees at the staging area?
- Response No.4: No, the staging areas shown on the plans may not be expanded/cleared as they are on private property (via Right of Entry Agreements) that is not owned by the City.
- Question No.5: Are we allowed to clear dead trees that are hanging in the slough?
- Response No.5: Yes, but at no point should root systems of the trees be removed, unless already uprooted from the ground. Cutting back of dead limbs or flush cutting dead trunks is permissible.
- Question No. 6: Can the engineering firm provide a particle size analysis for the muck?
- Response No. 6: Please see the enclosed Geotechnical Engineering report for the project.

- Question No. 7: Specification No. 1.06-C, 120 Calendar Days" Does the 120 Cal. Days present Substantially Complete or Final Completion including any Punch List Items
- Response No. 7: Final completion
- Question No. 8: Specification N. 1.20-C, Mangrove Impact" Since there is no way of knowing how much trimming (Cost) will be required till work is underway, in order to make all bids equal, that an allowance be added as a Bid Item for any required Mangrove Impact
- Response No. 8: Dredging is to be focused within the central channel of the slough, which does not contain mangroves. Mangroves are only present on the banks of the Slough and we do not anticipate any impacts to occur. However, it is contractor's responsibility to visit the site to determine what trimming may be necessary. The City of Sanibel is a State (FDEP) delegated authority to regulate all mangrove trimming and removal within City limits. Any mangrove impacts would require prior approval from the City and restoration per City regulations, at the sole cost of the Contractor. Additionally, the City's grant agreement with FDEP requires any impacts to the shorelines will require regrading and restoration with native plants.
- Question No. 9: Technical Specification Item 7 " Item TS-7 state's that Dredging shall be Hydraulic not Mechanical, but USACE Permit # SAJ-2025-00223(LP-SJF) Page 1 states Mechanical Dredging is proposed vis Hydraulic Dredging. Which is correct.
- Response No. 9: Hydraulic dredging is required per the FDEP permit.
- Question No. 10: Construction Commencement Notice" Does Contractor file the Notice of Commencement or does the Owner. Page 7, of 12, Item 4, FDEP Permit No. 457045-001 E1
- Response No. 10: The Owner will submit the Construction Commencement Notice to FDEP for this permit.
- Question No. 11: "Dredge Material Haul Off " Has Dredge Material (Haul Off) been tested for any contaminates (Example: Arsenic, Asbestos, Etc.) this will determine where material can be disposed of.
- Response No. 11: No, it has not been tested for contaminants.

A. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of bid.
- b. All other terms, conditions and specifications of ITB-NR-1-2026/BS remain the same.
- c. Receipt acknowledged by:

Authorized Signature & Date Signed

Title

Name of Firm