



City of Sanibel

ADDENDUM NO. 4
April 23, 2026

RE: Sanibel Slough Hydraulic Dredging Project (ITB-NR-1-2026/BS) Proposal due date: May 07, 2026 @ 2:30PM

FROM: City of Sanibel
800 Dunlop Road
Sanibel, FL 33957

TO: Prospective Bidders and Others Concerned

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original document.

A. Questions and Answers

Question No. 1: The latest addendum states online item #8 that "Sampling for contaminants for the purposes of determining where the muck can be disposed of will be the responsibility of the contractor." - If contaminants are found to be in the muck, the water will have to be filtered and decontaminated before being reintroduced back into the slough. Will the city accept a change order for the decontamination process or is that another responsibility born onto the contractor?

Response No. 1: If contaminants are found in the dredge material and regulatory agencies require the water to be filtered and decontaminated before being reintroduced back into the slough, such costs may be considered through a change order.

Question No. 2: Line #7 " Sediment nutrient results are now available" where are these results in the documents?

Response No. 2: Per the City's grant agreement with FDEP, we are required to quantify the pounds on nitrogen and phosphorus within the muck dredged from the soil. Sediment core samples were obtained, and the concentrations of N and P were quantified. At the end of the project, we will determine pounds removed once we know the volume of muck removed. This is a reporting requirement that the City will handle. However, during the pre-bid meeting there was a request from a contractor to share the sediment sampling results. The results are reported in cross section at the bottom, adjacent to each core sample, and are reported in $\mu\text{g}/\text{cm}^3$.

A. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of bid.
- b. All other terms, conditions and specifications of ITB-NR-1-2026/BS remain the same.
- c. Receipt acknowledged by:

Authorized Signature & Date Signed

Title

Name of Firm