



City of Sanibel

**ADDENDUM NO. 1  
January 27, 2026**

RE: Beach Road Weir Restoration (ITB-PW-3-2026/SK) Proposal due date: February 5,2026

FROM: City of Sanibel  
800 Dunlop Road  
Sanibel, FL 33957

TO: Prospective Bidders and Others Concerned

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original document.

**A. Questions and Answers**

Question No. 1: Does the contractor only need to dewater the area (marked in gray on Sheet S200)?  
Just want to confirm no dewatering needs to be done on the outside of the structure on the upstream side

Response No. 1: The limits of dewatering shall be the grey area inside the structure indicated on Drawing S-200.

Question No. 2: Please confirm the contractor is only required to clean and paint gate operator?  
Gate is not required to be cleaned and painted

Response No. 2: Contractor is only required to clean and paint the pedestal mounted gate operator in the base bid.

**A. ACKNOWLEDGEMENT OF ADDENDA**

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of bid.
- b. All other terms, conditions and specifications of ITB-PW-3-2026/SK remain the same.
- c. Receipt acknowledged by:

---

Authorized Signature & Date Signed

---

Title

---

Name of Firm