



City of Sanibel

ADDENDUM NO. 1

February 26, 2025

RE: Wastewater Biosolids Hauling and Disposal Services (RFP-UT-25-001/BS) Proposal due date: March 13, 2025 @ 2:30PM

FROM: City of Sanibel
800 Dunlop Road
Sanibel, FL 33957

TO: Prospective Bidders and Others Concerned

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original document.

A. Questions and Answers

Question No. 1: What is the anticipated frequency and volume of hauling for this service? I assume the volume varies seasonally.

Response No. 1: No amount of work is or will be guaranteed or implied. The City's Donax Water Reclamation Facility (WRF) currently produces approximately 1.5 million gallons of liquid wastewater biosolids annually. The volume and frequency of biosolid hauling vary throughout the year, with weekly hauling during peak season and intervals extending up to eight weeks during the off-season. Weekly hauling volumes can range from 18,000 gallons during the off-season to 114,000 gallons during peak season, depending on operational requirements. Average hauling is approximately 58,000 gallons every other week.

Question No. 2: On average, how many gallons per week in season and off season do you anticipate needing to be hauled off and disposed.

Response No. 2: See Response No. 1.

Question No. 3: I would like to have a copy of the current pricing contract for your wastewater treatment plant - wastewater biosolids hauling and disposal services.

Response No. 3: The City's current pricing through Karle Enviro Organic Recycling for wastewater biosolids and disposal services is \$0.17/gallon (wet).

A. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of bid.
- b. All other terms, conditions and specifications of ITB-UT-0-2025/SK remain the same.
- c. Receipt acknowledged by:

Authorized Signature & Date Signed

Title

Name of Firm



City of Sanibel

**ADDENDUM NO.
1 Revised
February 26, 2025**

RE: Wastewater Biosolids Hauling and Disposal Services (RFP-UT-25-001/BS) Proposal due date:
March 13, 2025 @ 2:30PM

FROM: City of Sanibel
800 Dunlop Road
Sanibel, FL 33957

TO: Prospective Bidders and Others Concerned

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original document.

A. Questions and Answers

Question No. 1: What is the anticipated frequency and volume of hauling for this service? I assume the volume varies seasonally.

Response No. 1: No amount of work is or will be guaranteed or implied. The City's Donax Water Reclamation Facility (WRF) currently produces approximately 1.5 million gallons of liquid wastewater biosolids annually. The volume and frequency of biosolid hauling vary throughout the year, with weekly hauling during peak season and intervals extending up to eight weeks during the off-season. Weekly hauling volumes can range from 18,000 gallons during the off-season to 114,000 gallons during peak season, depending on operational requirements. Average hauling is approximately 58,000 gallons every other week.

Question No. 2: On average, how many gallons per week in season and off season do you anticipate needing to be hauled off and disposed.

Response No. 2: See Response No. 1.

Question No. 3: I would like to have a copy of the current pricing contract for your wastewater treatment plant - wastewater biosolids hauling and disposal services.

Response No. 3: The City's current pricing through Karle Enviro Organic Recycling for wastewater biosolids and disposal services is \$0.17/gallon (wet).

A. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of bid.
- b. All other terms, conditions and specifications of RFP-UT-25-001/BS remain the same.
- c. Receipt acknowledged by:

Authorized Signature & Date Signed

Title

Name of Firm



City of Sanibel

ADDENDUM NO. 2

March 3, 2025

RE: Wastewater Biosolids Hauling and Disposal Services (RFP-UT-25-001/BS) Proposal due date: March 13, 2025 @ 2:30PM

FROM: City of Sanibel
800 Dunlop Road
Sanibel, FL 33957

TO: Prospective Bidders and Others Concerned

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original document.

A. Questions and Answers

Question No. 1: The City of Sanibel is currently permitted by the FDEP to transfer biosolids generated by the Donax WRF to the Lee/Hendry County Regional Solid Waste Disposal Facility or a Class I solid waste landfill. Can Compost USA of Highlands County Permit #FLAB07164 be put on the permit?

Response No. 1: Transferring biosolids to an alternative biosolids treatment facility does not require a permit modification. However, use of an alternative biosolids treatment facility requires submittal of a copy of the agreement pursuant to Rule 62-640.880(1)(c), F.A.C., along with a written notification to the Department at least 30 days before transport of the biosolids. [62-620.320(6), 62-640.880(1)]. This agreement shall be established between the awarded Contractor(s) and the designated alternative biosolids treatment facility. However, if the awarded Contractor(s) also serve as the alternative biosolids treatment facility, the agreement shall be between the awarded Contractor(s) and the City.

A. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of bid.
- b. All other terms, conditions and specifications of RFP-UT-25-001/BS remain the same.
- c. Receipt acknowledged by:

Authorized Signature & Date Signed

Title

Name of Firm