



City of Sanibel

ADDENDUM NO. 3 April 21, 2026

RE: Sanibel Slough Hydraulic Dredging Project (ITB-NR-1-2026/BS) Proposal due date: May 07, 2026 @ 2:30PM

FROM: City of Sanibel
800 Dunlop Road
Sanibel, FL 33957

TO: Prospective Bidders and Others Concerned

This addendum is hereby incorporated into the bid documents of the project referenced above. The following items are clarifications, corrections, additions, deletions, and/or revisions to and shall take precedence over the original document.

A. Follow-up to Mandatory Pre-Bid Conference on 04/17/2026

1. The temporary construction easements and right of entry agreements have been provided
2. I have confirmed with Public Works that the road that crosses over the Sanibel Slough does not have a published weight limit. The crossing is a double 4'x10' concrete box culvert. Contractors to use caution prior to use of the bridge. See screenshot for the road crossing being referenced.



3. The acreage of the three parcels for staging to the south of the Slough is approximately 1.3 acres. See the revised plan set for additional information.

4. Here is the language in the code regarding hours on construction on Sanibel:
“Construction or repairing of buildings, etc. The erection, demolition, alteration, or repair of any building, or any excavation, other than between the hours of 7:00 a.m. and 5:00 p.m., Monday through Saturday, except for emergency work or in case of urgent necessity in the interest of public health and safety and only when approved by the city manager. When the city has declared a state of local emergency related to a natural or manmade disaster, the city council may amend the hours for construction or repairing of buildings via resolution or by mayoral proclamation.” It is possible allow work on Sundays, but it would have to be approved by the City Manager and/or City Council.
5. The owner of Periwinkle Park, David Muench, has asked that anyone visiting the site prior to bid submission enter the Park through the main gate off of Periwinkle Way.
6. For the geotechnical report on grain size, it documents the percentage of particles passing through the sieve.
7. Sediment nutrient results are now available.
8. Sampling for contaminants for the purposes of determining where the muck can be disposed of will be the responsibility of the contractor.
9. The contractor will be responsible for submitting a Notice of Intent (NOI) to obtain a Construction Generic Permit (CGP) from FDEP for dewatering operations on parcels noted for project staging/dewatering.
10. Turbidity monitoring is the responsibility of the contractor. It is not required that a third party perform the monitoring.

A. ACKNOWLEDGEMENT OF ADDENDA

- a. The Bidder shall acknowledge receipt of this addendum by completing the applicable section in the solicitation or by completion of the acknowledgement information on the addendum. Either form of acknowledgement must be completed and returned not later than the date and time for receipt of bid.
- b. All other terms, conditions and specifications of ITB-NR-1-2026/BS remain the same.
- c. Receipt acknowledged by:

Authorized Signature & Date Signed

Title

Name of Firm